



GRANS NEW BREWERY

April 23, 2018



Presentation


1. Planned process. Baseline
2. Alternative design
3. Results and recommendations

Baseline: Key points

- Great demand of steam: process + CIPs
- Steam produced by burning LPG
- Heat being rejected to the ambient
- Installation of an energy storage




Baseline: Process



Baseline: Energy storage

- Condensing steam from the boiling
- Preheating the wort
- Producing hot water



Baseline: Demands

Production
schedule

- 14 brews per week for 135.000 hl/year
- Analysis for 15-minute intervals

Inputs and
outputs

- Water at 8 °C, 80 °C, 85 °C
and 95 °C
- Steam

CIP: beer +
soft drinks



Net
demands

Baseline: Demands of the process

	4:00	4:15	4:30	4:45	5:00	5:15	5:30	5:45	6:00	6:15	6:30	6:45	7:00	7:15	7:30	7:45	8:00	8:15	8:30	8:45	9:00	9:15	9:30	9:45	10:00	10:15	10:30	10:45	11:00	11:15	11:30	
BATCH 1	Milling (S1B1)			Mashing (S1B1)					Lautering (S1B1)							Boiling (S1B1)					Whirlpool (S1B1)		Wort cooling (S1B1)									
Temperature (°C)	52	52	52	53	63	63	63	63	78	78	78	78	78	78	78	78	78	90	100	100	100	100	100	98	98	98	98	12	12	12	12	
Hot water (85 °C) input (l/min)	107	107	107							157	157	157	157	157	157	157	157															
Water (95 °C) input (l/min)																		1120	454	454	242,1											
Water (80 °C) input (l/min)																			454	454	454	454	454									
Cold water (8 °C) input (l/min)	62	62	62							14	14	14	14	14	14	14	14		86,1	86,1	45,9						375,3	375,3	375,3	375,3		
Steam 3.5 bar input (kg/min)				12,3					18,4										15,9	15,9	15,9	15,9	15,9									
Hot water (85 °C) output (l/min)																			86,1	86,1	45,9					375	375	375	375			
Water (95 °C) output (l/min)																			454	454	454	454	454									
Water (80 °C) output (l/min)																		1120	454	454	242,1											
Cold water (8 °C) output (l/min)																																
BATCH 2										Milling (S1B2)			Mashing (S1B2)				Lautering (S1B2)					Boiling (S1B2)										
Hot water (85 °C) input (l/min)										107	107	107							157	157	157	157	157	157	157	157	157					
Water (95 °C) input (l/min)																										1120	454	454	242,1			
Water (80 °C) input (l/min)																				454	454	454	454	454								
Cold water (8 °C) input (l/min)									62	62	62								14	14	14	14	14	14	14	14	14	86,1	86,1	45,9		
Steam 3.5 bar input (kg/min)												12,3					18,4											15,9	15,9	15,9	15,9	15,9
Hot water (85 °C) output (l/min)																				86,1	86,1	45,9					454	454	454	454	454	
Water (95 °C) output (l/min)																				454	454	454	454	454								
Water (80 °C) output (l/min)																			1120	454	454	242,1										
Cold water (8 °C) output (l/min)																																
TOTAL																																
Hot water (85 °C) needed (l/min)	107	107	107	0	0	0	0	0	107	264	264	157	157	157	157	157	157	157	70,9	70,9	111,1	157	157	157	157	0	-86,1	-461	-421	-375	-375	
Water (95 °C) needed (l/min)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1120	0	0	-212	-454	-454	0	0	1120	0	0	-212	-454	-454
Water (80 °C) needed (l/min)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	-1120	0	0	211,9	454	454	0	0	-1120	0	0	211,9	454	454
Cold water (8 °C) needed (l/min)	62	62	62	0	0	0	0	0	62	76	76	14	14	14	14	14	14	14	14	100	100	59,9	14	14	14	14	0	86,1	461	421,2	375	375
Steam 3.5 bar needed (kg/min)	0	0	0	12,3	0	0	0	0	18,4	0	0	12,3	0	0	0	0	18,4	0	15,9	15,9	15,9	15,9	15,9	0	0	0	15,9	15,9	15,9	15,9	15,9	

Baseline: Demands

Brewing process		
Net demand	Per brew	Per week (14 brews)
Water at 80 °C (liters)	0	0
Water at 95 °C (liters)	0	0
Water at 85 °C (liters)	-2.132	-29.857
Water at 8 °C (liters)	30.257	423.608
Steam at 3,5 bar (kg)	1.588,5	23.142



Steam is **necessary** for a fast heat transfer

Baseline: Demands

Beer CIP

	Water at 100 °C demand per cycle (liters)	Cycles per week	Total demand of water at 100 °C (liters/week)	Total steam demand to heat the water up from 8 °C to 100 °C (kg/week)
Process	6.000	1	6.000	952
Filling line	5.520	7	38.640	6.130
Total	-	-	44.640	7.402


Soft drinks CIP

	Water at 100 °C demand per cycle (liters)	Cycles per week	Total demand of water at 100 °C (liters/week)	Total steam demand to heat the water up from 8 °C to 100 °C (kg/week)
Large CIP	7.200	10	72.000	11.796
Small CIP	3.600	30	108.000	17.693
Total	-	-	180.000	29.849

Steam is not necessary: Obtain hot water by other means

Baseline: LPG consumption

Steam demand (tons/week)





■ Brewing process ■ Beer CIP ■ Soft drinks CIP

- Brewing proces: 1,7 tons/week
- Beer CIP: 0,6 tons/week
- Sof drinks CIP: 2,5 tons/week

234 tons of LPG/year


Baseline: Emissions

CO ₂ equivalent emission (kg/year)	CO ₂	CH ₄	N ₂ O
Brewing process	241.006	195	2.846
Beer CIP	86.537	70	1.019
Soft drinks CIP	348.745	282	4.118
Total	676.288	547	7.983



685 tons of CO₂/year

Baseline: Economic cost



↑ LPG price increase since 2017 due to CO₂ taxes. It will continue to rise.

Best case scenario: 1,7 Million kroner per year

Baseline: Rejected heat. Tank farm

- 600 m³ of beer in the tank farm
- 52 kW for cooling (Nominally)




Loses, insulation...

- **60 kW** at any time



Lost to the ambient air



Baseline: Rejected heat. Residual water

- 184 m³ of water at 20 °C per day
- 5 days a week



If cooled to 5 °C

- **133,5 kW available**



Currently lost




Alternative design: Key points

- Use of heat pumps
- Use of residual heat
- Reduce steam demand
- Eliminate LPG: reduced emissions

Alternative design: Key points

Residual heat is used to produce steam and hot water:

- Steam is produced with a **high temperature heat pump**
- Hot water is produced with a **carbon dioxide heat pump**




Alternative design. Production of steam

Ammonia – Isobutane heat pump cascade system

Steam is generated at 1 bar and then compressed to 3,5 bar

The condenser of the isobutane cycle is a coil inside the energy storage tank to evaporate water

Steam to be used in the process




Carbon dioxide heat pump

- Initially it was considered to produce water at 85 °C (First stages), but it is much more efficient and useful to produce water at 100 °C (Stage 3)
- In parallel to the cascade system


Alternative design: Stage 1

- Only the residual heat from the tank farm is considered
- The heat can be used to produce steam or hot water, or it can be discarded through the ammonia system
- 60 kW, 24/7




Alternative design: Stage 1

Residual heat from the tank farm



Alternative design: Stage 1

- Maximum production: 36 tons of steam per week or 159 m³ of water at 85 °C




Alternative design: Stage 2

- Both the heat from the tank farm and from the residual water are used
- The water is cooled from 20 °C to 5 °C
- 60 kW (24/7) + 133,5 kW (5 days/week)
- Parallel cycles

Alternative design: Stage 2

Tank farm + Residual water



Alternative design: Stage 2

	Heat available at source (kW)	Days of availability per week	Maximum steam generation (kg/week)
Tank farm (0 °C)	60	7	36.187
Residual water (20 °C)	133,5	5	52.344
Total	-	-	88.531


Weekly demand	Steam (kg)
Brewing process	23.142
Beer CIP	7.402
Soft drinks CIP	29.849
Total	60.393

- Enough to cover the demands
- Very inefficient: better to produce water at 100 °C for the CIP and eliminate steam

Alternative design: Stage 3


Tank farm + Residual water

Steam + Water at 100 °C



Alternative design: Stage 3

Weekly demand	Steam (kg)		Water at 100 °C (liters)
Brewing process	23.142		0
Beer CIP	7.402	or	44.640
Soft drinks CIP	29.849	or	180.000
Maximum total	60.393		224.640
Maximum weekly generation	88.531	or	334.783




- 62% steam demand


Electricity consumption

Alternative design: Stage 3

Demand of electric energy



- Production of steam at 1 bar
- Compression of steam to 3,5 bar
- Production of water at 100 °C



- Maximim possible production of steam
- Continuous production of steam


Installed capacity:

266 kW (Maximum production of steam, 650 kg/hour)

107 kW (Continuous production of steam, 137 kg/hour)

Electricity consumption:
~ 727 MWh/year

Alternative design: Stage 3



Peak demand of 1,7 tons/hour

Capacity of the steam accumulator:


5 tons (Maximum production of steam)

12 tons (Continuous production of steam)


Alternative design: Additional options

- Heat from the cooling of the plant in the summer
- Heat from the ambient air in the winter: through the roof
- Use of glycol

Theoretical: To cover other necessities of the plant or as an alternative




— Average maximum daily temperature (°C)
 — Average daily minimum temperature (°C)




Alternative design: Additional options

- 3 Parallel cycles
- Variable evaporation temperature




Alternative design: Additional options

Tank farm + Residual water + Air




Results



- ❖ Air is not considered as a heat source for this stage, only as a possible alternative

Results: Environmental impact



➤ Different sources for the electricity:




**Guarantee
of Origin**

Results: Environmental impact

	CO ₂ emissions per liter of beer (g)	CO ₂ total yearly emissions (t)
Current brewery (Burning LPG)	25	685
New brewery (General mix)	1,1	22
New brewery (Norwegian produced only electricity)	0,5	10
New brewery (Certified electricity produced from hydropower)	0,2	3,5



Results: Environmental impact




Results: Operating costs

With GOs: 211 k
kroner/year



$\pm 1\%$

Without GOs: 209 k
kroner/year





Results: Final considerations

- ✓ The use of residual heat from the tank farm and from the residual water offers almost a complete elimination of the CO₂ emissions and a great reduction of the operating costs
- ✓ Steam is not necessary for the CIP systems, and production of water at 100 °C is much more efficient




Results: Final considerations

- ✓ GOs reduce emissions to 1/6 with an increase of only 1% of the cost
- ✓ If used with a Green label, it can greatly impact how the consumers value the brand
- ✓ Marketing should play an important role in this scenario to gain the maximum competitive advantage



Results: Final considerations

Use of residual heat from the tank farm and from the residual water





Department of Energy and Process Engineering

Norwegian University of Science and Technology

April 23, 2018