

2022

Resultater av kontrollprøver, Mebonden RA

Dag	Mebonden RA avløp døgn innløp						Mebonden RA avløp døgn utløp				Mebonden RA rensegrader			
	Vannførin g m3/d	Overløp m3/d	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF RG %	KOF RG %	SS RG %	TOTP RG %
11.01.22	241		122.0	320	160.00	6.38	31.0	105	34.00	4.04	75	67	79	37
09.02.22	273		259.0	488	310.00	8.12	25.0	64	6.00	4.59	90	87	98	43
09.03.22	277		122.0	278	120.00	7.24	23.0	84	1.00	4.33	81	70	99	40
10.05.22	320		270.0	489	190.00	12.40	31.0	117	27.00	5.33	89	76	86	57
15.06.22	269		221.0	326	200.00	6.21	39.0	133	37.00	3.79	82	59	82	39
13.07.22	336		65.0	168	130.00	3.32	21.0	40	17.00	5.19	68	76	87	-56
12.08.22	291		145.0	367	110.00	7.12	46.0	133	34.00	1.30	68	64	69	82
06.09.22	252		327.0	555	200.00	10.70	92.0	230	82.00	9.13	72	59	59	15
12.10.22	251		377.0	1260	450.00	9.34	31.0	105	38.00	6.66	92	92	92	29
08.11.22	252		182.0	457	6200.00	8.23	35.0	138	35.00	7.21	81	70	99	12
06.12.22	227		242.0	514	260.00	10.90	32.0	119	34.00	8.35	87	77	87	23
Sum														
Snitt	272		212.0	475	757.27	8.18	36.9	115	31.36	5.45	80	72	85	29
Maks	336		377.0	1260	6200.00	12.40	92.0	230	82.00	9.13	92	92	99	82
Min	227		65.0	168	110.00	3.32	21.0	40	1.00	1.30	68	59	59	-56
Antall	11	0	11	11	11	11	11	11	11	11	11	11	11	11

2021

Resultater av kontrollprøver, Mebonden RA

Dag	Mebonden RA avløp døgn innløp						Mebonden RA avløp døgn utløp				Mebonden RA rensegrader			
	Vannførin g m3/d	Overløp m3/d	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF RG %	KOF RG %	SS RG %	TOTP RG %
12.01.21	200		186.0	588	300.00	9.16	79.0	205	52.00	5.24	58	65	83	43
09.02.21	192		243.0	684	400.00	12.30	66.0	204	69.00	6.35	73	70	83	48
15.02.21	189		190.0	489	280.00									
09.03.21	244		198.0	498	350.00	10.50	40.0	179	54.00	4.61	80	64	85	56
14.04.21	265		144.0	318	220.00	9.28	45.0	157	54.00	4.99	69	51	75	46
12.05.21	230		157.0	514	290.00	9.41	57.0	171	43.00	4.83	64	67	85	49
10.06.21	210		280.0	665	480.00	11.10	75.0	178	47.00	6.49	73	73	90	42
13.07.21	219		242.0	525	330.00	10.70	28.0	103	25.00	3.85	88	80	92	64
11.08.21	190		244.0	610	160.00	10.90	49.0	190	36.00	7.61	80	69	78	30
20.10.21	464		113.0	301	170.00	5.43	14.0	63	13.00	2.88	88	79	92	47
28.10.21	374		93.0	291	140.00	5.87	12.0	95	11.00	2.98	87	67	92	49
09.11.21	296		175.0	539	220.00	8.98	17.0	60	15.00	3.46	90	89	93	61
18.11.21	346		198.0	503	230.00	8.49	24.0	90	23.00	4.63	88	82	90	45
02.12.21	317		264.0	608	400.00	10.20	25.0	86	18.00	4.53	91	86	96	56
07.12.21	248		213.0	493	340.00	7.50	92.0	208	30.00	4.09	57	58	91	45
Sum														
Snitt	266		196.0	508	287.33	9.27	44.5	142	35.00	4.75	77	71	88	49
Maks	464		280.0	684	480.00	12.30	92.0	208	69.00	7.61	91	89	96	64
Min	189		93.0	291	140.00	5.43	12.0	60	11.00	2.88	57	51	75	30
Antall	15	0	15	15	15	14	14	14	14	14	14	14	14	14

2020

Resultater av kontrollprøver, Mebonden RA

Dag	Mebonden RA avløp døgn innløp						Mebonden RA avløp døgn utløp				Mebonden RA rensegrader			
	Vannførin g m3/d	Overløp m3/d	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF RG %	KOF RG %	SS RG %	TOTP RG %
12.02.20	377		215.0	557	330.00	6.08	75.0	180	55.00	3.52	65	68	83	42
18.03.20	262		181.0	520	280.00		47.0	140	54.00		74	73	81	
22.04.20	364		73.0	219	91.00	3.84	56.0	141	49.00	2.68	23	36	46	30
19.05.20	347		242.0	605	470.00	6.66	39.0	152	48.00	3.25	84	75	90	51
16.06.20	208		245.0		310.00	12.40	50.0		40.00	7.44	80		87	40
14.07.20	189		190.0	489	290.00		59.0	143	31.00		69	71	89	
18.08.20	194		262.0	774	430.00	10.60	41.0	142	40.00	5.37	84	82	91	49
15.09.20	195		249.0	615	390.00		38.0	132	33.00		85	79	92	
13.10.20	233		259.0	690	370.00		39.0	122	33.00		85	82	91	
11.11.20	227		185.0	551	320.00		38.0	141	32.00		79	74	90	
15.12.20	212		137.0	663	350.00	8.90	59.0	167	24.00	5.89	57	75	93	34
Sum														
Snitt	255		203.5	568	330.09	8.08	49.2	146	39.91	4.69	71	71	85	41
Maks	377		262.0	774	470.00	12.40	75.0	180	55.00	7.44	85	82	93	51
Min	189		73.0	219	91.00	3.84	38.0	122	24.00	2.68	23	36	46	30
Antall	11	0	11	10	11	6	11	10	11	6	11	10	11	6

2019

Resultater av kontrollprøver, Mebonden RA

Dag	Mebonden RA avløp døgn innløp						Mebonden RA avløp døgn utløp				Mebonden RA rensegrader			
	Vannførin g m3/d	Overløp m3/d	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF RG %	KOF RG %	SS RG %	TOTP RG %
14.01.19	306		221.0		280.00	7.61	32.0		25.00	3.34	86		91	56
12.02.19	208		171.0		220.00	8.44	46.0		44.00	4.28	73		80	49
11.03.19	248		185.0		220.00	8.90	56.0		48.00	4.46	70		78	50
10.04.19	302		144.0		180.00	6.62	42.0		40.00	2.93	71		78	56
07.05.19	260		355.0		380.00	6.71	49.0		42.00	4.16	86		89	38
17.06.19	246		219.0		470.00	10.40	32.0		40.00	4.90	85		91	53
03.07.19	255		141.0		270.00	6.36	37.0		33.00	3.47	74		88	45
06.08.19	178		231.0		490.00	10.60	34.0		27.00	4.18	85		94	61
03.10.19	262		193.0		220.00	7.70	49.0		41.00	6.52	75		81	15
05.11.19	241		153.0		230.00	8.19	39.0		35.00	3.16	75		85	61
05.12.19	301		146.0	400	230.00		58.0	174	41.00		60	57	82	
Sum														
Snitt	255		196.3	400	290.00	8.15	43.1	174	37.82	4.14	76	57	85	48
Maks	306		355.0	400	490.00	10.60	58.0	174	48.00	6.52	86	57	94	61
Min	178		141.0	400	180.00	6.36	32.0	174	25.00	2.93	60	57	78	15
Antall	11	0	11	1	11	10	11	1	11	10	11	1	11	10

2018

Resultater av kontrollprøver, Mebonden RA

Dag	Mebonden RA avløp døgn innløp						Mebonden RA avløp døgn utløp				Mebonden RA rensegrader			
	Vannførin g m3/d	Overløp m3/d	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF mg/l	KOF mg/l	SS mg/l	TOTP mg/l	BOF RG %	KOF RG %	SS RG %	TOTP RG %
24.01.18	215		601.0		1605.00	12.30	62.0		39.00	5.00	90		98	59
21.02.18	164		204.0		213.00	11.30	59.0		38.00	7.36	71		82	35
20.03.18	187		1210.0		1842.00	12.30								
17.04.18	418		158.0		204.00	4.94	32.0		40.00	1.98	80		80	60
14.05.18	233		183.0		310.00	8.34	35.0		34.00	4.83	81		89	42
11.06.18	189		195.0		150.00	7.58	42.0		27.00	5.38	78		82	29
10.07.18							19.0		20.00	4.19				
06.08.18	223		145.0		190.00	8.72								
02.09.18	215		143.0		220.00	9.38								
02.10.18			144.0		190.00	6.79	17.0		19.00	3.71	88		90	45
30.10.18	294		113.0		140.00	5.40	28.0		25.00	4.32	75		82	20
18.12.18	228		172.0		270.00	9.05	45.0		33.00	4.74	74		88	48
Sum														
Snitt	237		297.1		484.91	8.74	37.7		30.56	4.61	80		86	42
Maks	418		1210.0		1842.00	12.30	62.0		40.00	7.36	90		98	60
Min	164		113.0		140.00	4.94	17.0		19.00	1.98	71		80	20
Antall	10	0	11	0	11	11	9	0	9	9	8	0	8	8